

Noratel AS  
P.O. 133  
N-3301 HOKKSUND  
Tel: +47 32 25 15 00  
Fax: +47 32 25 15 50  
firmapost@noratel.no

Manufacturer: **Noratel AS – Norway**  
Address: **P.O. 133, N – 3301 Hokksund Norway**

ISO 9001 Certified

herewith declares that:

Type of equipment:

**1-Phase; Isolating Transformers**

**<1000VAC at primary and <1000VAC at secondary or <1000VDC  $\sqrt{2}$  at secondary**

Type designation etc.:

**FR42X-XX, FR48X-XX, FR54X-XX, FR60X-XX, FR66X-XX, FR75X-XX, FR78X-XX, FR84X-XX,  
FR92X-XX, FR96X-XX, FR105X-XX, FR108X-XX, FR120X-XX, FR130X-XX,  
FR135X-XX, FR150X-XX**

Data:

**2VA ... 2000VA**

**Class II, Ambient temp. 25/40/45°C, Cooling; AN, Frequency; 47-63Hz**

**IP00/IP2X/ IP3X/IP4X/IP5X, Insul.cl.; E/B**

**Mobility; stationary, With (./S) or without static screens**

- *is in conformity with the provisions of the following EC directive(s), including the latest amendments, and with national legislation implementing this/these directives:*

- 1. Low Voltage Directive 2014/35/EU**
- 2. EMC Directive 2014/30/EU**

*and that the following (parts/clauses of) harmonized standards have been applied:*

- 1. EN 61558-1:2005+A1:2009 - General requirements**  
**EN 61558-2-4:2009, Particular requirements for Isolating transformers for general use.**
- 2. Electromagnetic compatibility acc. to the EMC directive**  
The transformer contains no components that generate or are sensitive to electromagnetic disturbances.

- *the following (parts/clauses of) national and/or international technical standards and specifications have been applied:*


- 1. DNV(Det Norske Veritas) rules for classifications of ships, Light Craft and Naval Surface Craft**
- 2. IEC 60092, Electrical installation in ships**

The date of  - marking: **01.01.1996**

Place: **Hokksund**

Date: **19.04.2016**

Signature:



Clarification:

**Lam Quang Ho,**

Position:

**Design Engineer**